

CONFIDENTIAL

AIR

Document No. <u>5</u>
No Change In Class. ☐
☐ Declassified
Class. Changed To: <u>15</u> <u>6</u>
Auth.: HR 70-2
Date: <u>07/1/78</u> By: <u>025</u>

25X1A6C

THRU Construction Engineer
Chief, [REDACTED]
Acting Chief, Real Estate and
Construction Division
Administrative
Replacement Construction Program

25X1A6A

REFERENCES:

(A)
(B)

25X1A6C

1. Reference (A) plans have been reviewed at headquarters and the following improvements are suggested for incorporation into the plans:

- a. Provide fixed wood louvers in openings top and bottom of manila partitions between the passageway and the bedrooms of all quarters. It is doubtful that the present plan will provide adequate privacy.
- b. Provide regular asphalt tile base on all concrete walls and wood partitions in lieu of painted strips and wood base.
- c. Provide scuppers on the porches of all quarters similar to those detailed for porch No. 2 of the [REDACTED] quarters.
- d. All vertical wood trim at the exterior doors to the quarters and the screen porch should stop one inch clear of the porch floor and/or the concrete stoop. The bottom ends of this trim should be painted thoroughly.

25X1A

C/FE

D/L
FE/LOG

AC/RECD 15/Wfec

CONFIDENTIAL

~~CONFIDENTIAL~~

[REDACTED]

25X1A6C

Page 2

2. Your attention is called to Reference (B) which lists the excess collateral equipment available which can be used to supplement the equipment presently available [REDACTED]. Inform headquarters your needs in this respect.

25X1A6A

15 / 1/16/56

[REDACTED]

25X1A9A

13 January 1956

Distribution:

- Orig. & 2 - Addressee
- 1 - RECD Project
- 1 - RECD Chrono
- 1 - D/L
- 1 - FE/LOG
- 1 - C/FE
- 1 - RI

OL/RECD: [REDACTED] 4543 (13 Jan 56)

25X1A9A

~~CONFIDENTIAL~~